

## Fire Application #222136 - Bel Lago Unit 615

[illegible]



## CITY OF KIRKLAND



### Fire Application #222136 - Bel Lago Unit 615

#### Project Contact

**Company Name:** Wolfe Fire Protection, Inc.

**Name:** Jeff Moen **Email:** jeffm@wolfefireprotection.com

**Address:** 17321 Tye St SE Suite B **Phone #:** (360) 794-7926  
Monroe WA 98272

Project Type	Activity Type	Scope of Work
Nonresidential	Alteration	Fire Sprinkler Systems

**Project Name:** Bel Lago Unit 615

**Description of Work:** Lower 26 sprinklers, move 1, and remove 9 to accommodate new walls and ceilings for condo remodel.

#### Project Details

##### System Information

This is an addition to an existing system

##### Fire System Type

NFPA 13

##### Alterations

There are no alterations to devices or systems.

##### Quick Response or Recalled Head Change Out

The K-Factor and spacing match existing.

##### Quick Response or Recalled Head Relocation

No heads are being relocated.

##### Change of Use

This is not a change of use.

##### Hydraulic Calculations

There is no change to the hydraulic calculations.

##### Hazard Classification

The space is classified as Light/Ordinary Hazard.

##### Mains and Cross Mains

Mains or cross mains are not being relocated.

##### Heads - Excluding Quick Response and Recalled

More than 25 total heads

##### Fire System Counts

Number of Heads Capped or plugged	9
Number of Heads Relocated	27